LAST REVISED: 01/2021

MANUFACTURER	LUMEC 640 CURE-BOIVIN BROISBRAND QC CANADA, J7G2A7
LOCAL SUPPLIER	ELECTRICAL REPRESENTATIVES WEST, INC. 624 LUCILE STREET, SEATTLE, WA 98108 (206-767-7722)
MODEL	CANDELA SERIES CAND2
COLOR	DARK GREEN (GN8 - SMOOTH)
BASE COVER	LBC2 BASE
GLOBE	POLYCARBONATE, CLEAR
FUSE CONNECTOR KIT	MODEL 1791-SF SEC CONNECTOR COMPANY, OR EQUAL
FUSES	"TRI-ONIC" TRM 2 (LAMP) & TRM 20 (RECEPTACLE) OR EQUAL
POLE HEIGHT	12 FEET
POLE TYPE	ALUMINUM, STRAIGHT, ROUND, 4", APR4U
REQUIRED OPTIONS	G.F.I. DUPLEX RECEPTACLE (DR) WITH A WEATHER TIGHT, IN-USE COVER. SIGN BRACKET (SA1) COLOR TO MATCH POLE. SINGLE PLANT ARM (PS) COLOR TO MATCH POLE. PHOTOELECTRIC CELL (SWITCH) FROM MANUFACTURER IS NOT ACCEPTABLE
PHOTOELECTRIC SWITCH	LUMATROL QUICK RESPONSE PHOTOCONTROL MODEL # 8690 PRECISION MULTIPLE CONTOLS, INC. 33 GREENWOOD AVE., MIDLAND PARK, NJ 07432 OR "M" OR "F" SERIES, AREA LIGHTING RESEARCH, INC. 60 ASBURY RD, HACKETTSTOWN, NJ 07840 OR EQUAL
OPTICAL SYSTEM	RR5 ROUND REFRACTOR TYPE V
SPACING	ALTERNATE BETWEEN STREET TREES (MAX. 60' O.C., MIN. 30' O.C.)
UTILITY BOX	CONCRETE J-BOX WITH METAL LID MARKED "ELECTRICAL" (SEE CK-R.47B)
POWER	TO BE PROVIDED BY DEVELOPER 120V FOR DUPLEX RECEPTACLE, 240V FOR THE STREET LIGHT
CONDUIT	2" PVC FROM SERVICE DISSCONNECT 1" PVC BETWEEN J-BOX AND STREET LIGHT
BULB	65W42LED4K
WIRING	THE CONTRACTOR IS RESPONSIBLE FOR INSTALLING WIRE THAT MEETS NEC STANDARDS. COPPER WIRE ONLY.
PERMIT	A SEPARATE ELECTRICAL PERMIT FROM THE CITY IS REQUIRED.
SPLICE CONNECTIONS	USE: C-TAP (COPPER CRIMP), 3M 2000 MASTIC WATERPROOFING, 3M SUPER 88 TAPE.

## CITY OF KIRKLAND

PLAN NO. CK - R.47E

